Texas Commission on Environmental Quality Chapter 217 – Design Criteria for Domestic Wastewater Systems Subchapter F: Activated Sludge Systems Effective December 4, 2015

Table F.2. – Maximum Clarifier Weir Overflow Rates Based Upon Traditional Design Methods

Applicable Permit Effluent Sets (mg/L)			Aeration Basin	Process – Treatment	Maximum Surface Loading	Minimum Detention Time at
BOD <sub>5</sub>	TSS	$NH_3 - N$	Organic Loading	Level	Rate at Two Hour Peak Flow (gpd/ft <sup>2</sup> )	Two Hour Peak Flow (h)
20	20 15		45	Fixed film – secondary or enhanced secondary	1,200	1.8
20 10 10	20 15 15	3	45, 35, 25, or 20	Activated sludge – secondary, enhanced secondary, or secondary with nitrification	1,200	1.8
20	20		15	Extended air - secondary	900	2.0
10	15	3	15	Extended air – enhanced secondary	800	2.2

<sup>(2)</sup> A clarifier must meet both the detention time and weir overflow rate criteria in Table F.2.